


BUSDUCT VERTICAL SUPPORT DETAIL

N.T.S.

NOTES:

- ① DROP ROD, SIZE AND SPACING AS PER MANUFACTURER'S RECOMMENDATIONS AND CODE.
- ② BUSDUCT
- ③ FLATWISE HANGER SQUARE 'D' # HF-13-F




BUSDUCT HANGER - EDGWISE SUPPORT DETAIL

N.T.S.

NOTES:

- ① DROP ROD, SIZE AND SPACING AS PER MANUFACTURER'S RECOMMENDATIONS AND CODE.
- ② BUSDUCT
- ③ EDGWISE HANGER SQUARE 'D' # HF-78-F




BUSDUCT WALL AND FLOOR OPENING DETAIL

N.T.S.

NOTES:

1. SEE ARCHITECTURAL DRAWINGS FOR FIRE SAFING DETAILS.




TYPICAL GROUND CONNECTION DETAIL FOR CABLE SUPPORT AND PULL BOXES

N.T.S.

NOTES:

- ① CABLE SUPPORT BOX IN SHAFT.
- ② CABLE SUPPORT
- ③ 4" RCS.
- ④ 500 KCMIL + 1#4/0 GROUND.
- ⑤ CABLE SUPPORT BOX TO HAVE TWO REMOVABLE COVERS FOR ACCESS FROM BOTH AIR AND ELEVATOR SHAFTS.




VERTICAL CONDUIT SUPPORT DETAIL

N.T.S.

NOTES:

- ① CHANNEL IRON
- ② 4" CONDUIT
- ③ CONDUIT CLAMP



TRANSITION BOX DETAIL

NOTES:

1. ALL BUS BAR EXTENTIONS TO BE 2000A, COPPER.
2. PLATING OF NEW P'SWORK TO MATCH EXISTING.


Sheet 41 of 41



THE PORT AUTHORITY
OF NEW YORK AND NEW JERSEY

James A. Zuck
Engineering Program Manager

EDWARDS AND ZUCK, P.C.
CONSULTING ENGINEERS
330 West 42nd Street, New York, NY 10036
212-750-3400
© 1992 Edwards and Zuck, P.C.



3/15/01 Drawings of Record
No. Date Revision Approved

Engineering Department
Design Division

The World Trade
Center
Electrical/HVAC
Upgrade Program

This
LOW VOLTAGE DISTRIBUTION
ONE & TWO WTC
ELECTRICAL

MISCELLANEOUS
ELECTRICAL
DETAILS

This drawing subject to conditions in contract.
All inventions, ideas, designs and methods
herein are reserved to Port Authority and
may not be used without it's written consent.

C.J. S.K./CADD F.J.
Designed by Drawn by Checked by

Date 10/4/93 Scale NONE

Contract Number Drawing Number

WTC-804.041 E-24

FILE NAME: PATED200